

2012 INTERNATIONAL ISOE ALARA SYMPOSIUM

Fukushima Severe Accident Dose Management &
Global Lessons Learned in Occupational Dose Reduction


Lessons of Fukushima-Daiichi NPP's Accidents for Achievement of the 1st Class Safety in the World

January 9, 2012 (Hyatt Regency Pier)


Dr. Tadashi NARABAYASHI
Nuclear and Environmental Systems
Hokkaido University

Optimization of Nuclear Safety Regulation
JSME Power and Energy System Division

Tsunami Flooding Area in each NPP




Tsunami Flooding Area in each NPP



SBO in Fukushima Daiichi NPPs



	#1	#2	#3	#4	#5	#6
DG	A:NG B:NG (T/B B1)	A:NG (B1) B:OK (FP/B 1F)	A:NG B:NG (T/B B1)	A:NG (T/B B1) B:OK (FP/B 1F)	A:OK->NG B:OK->NG (T/B B1) Water Cooling	A:OK->NG (R/B B1) Water Cooling B:OK (DG/B 1F)
Metal-Crad Switch	NG (T/B B1)	NG (T/B B1)	NG (T/B B1)	NG (T/B B1)	NG (T/B B1)	Barely (R/B B2F)
Power Center	NG (T/B B1)	Barely (T/B B1)	NG (T/B B1)	Barely (T/B 1F)	Barely (T/B 2F)	Barely (R/B B2F)
DC Buttery	NG (C/B B1)	NG (C/B B1)	OK (T/B BM1)	NG (C/B B1)	OK (T/B BM1)	OK (T/B BM1)
ECCS	HPCI:NG	NG	HPCI:OK	(No Fuels in RPV)	-	HPCS:OK (R/B B1)
RCIC	IC:OK(FC)	RCIC:OK	RCIC:OK			

SBO in Fukushima Daiichi NPPs



ICs in unit #1 were tripped by FC


- Loss of battery power for main control room caused the fail-close action to MO isolation valves to stop the IC. **It was a fail-dangerous system.**
- If the IC continue to operate, the accident would be terminated soon.



- RCIC steam turbine also stopped by loss of battery power in Unit #2 and #3.
- S/P temperature and pressure were so high that AM water injection took a lot of times.



CV Pressure Trend in unit #1

- After loss of ECCS and IC core cooling, CV pressure increased.
- Water level drifted by vaporizing water in reference leg.
- Radiation level increased at T/B.
- Hydrogen explosion occurred after S/C wet venting.




Pressure and Water Level in #1 RPV

- Analysis results show the RPV depressurization started before RPV bottom failure. **It might be caused through melted TIP tubes in the core.**
- Water level measurement was drifted by the loss of water in a reference leg by high-temperature superheated core.




CV Pressure Trend in unit #2

- After loss of RCIC water injection, DW pressure increased.
- Water level was decreased after RCIC tripped.
- RPV pressure was too high to water injection by Fire pump.
- Explosion sound occurred near S/C.




Failure of prompt water injection in #2

- Failure of prompt water injection after RCIC stopped in unit #2 caused the core damage and H₂ generation started.
- High-pressure discharge pump driven by diesel engine should be used.




Radiation level increased after CV rupture

- H₂ detonation were occurred after vent operation (#1, #3, #4)
- Radiation level increased soon after #2 CV rupture




Fukushima Daiichi Sevier Accidents




H2 Leak Path from CV

- CV top flange and hatches might be leak pass



Cause of H2 Detonation in #4 R/B

- #4 was in outage. No fuels in the core
- Hydrogen from #3 flowed into #4 via SGTS




#4's SGTS Filters were contaminated

Fukushima Daiichi Unit #4

Aug. 25, 2011
TEPCO

SGTS valves and contamination check results




- Filters in SGTS showed that H2 and FP supplied from #3 flowed into #4 R/B

#3's SGTS Filters were contaminated

Fukushima Daiichi Unit #3


Dec. 26, 2011
TEPCO

SGTS valves and contamination check results




Vent was a cause of suicide bombing ?

Fail-Open valve in SGTS supplied H2 and FP into R/B




Hydrogen Detonation and CV Rapture




Water Recycle System for Core Cooling

We proposed water recycle system for core cooling on March 28



Large Egg and Elephant's Leg

TMI-2: Large Egg in core Chernobyl: Elephant's Leg



Comparison between Chernobyl and Fukushima




Released FP		
	Cher-nobyl	Fuku-shima
Cs,I	1	1/13
Total	1	1/50

Core thermal output		
TMI-2	Cher-nobyl	Fuku-shima
1	100	~0.01

Countermeasure 1: Filtered Vent

Lessons of Chernobyl NPP Accidents promoted the installation of Filtered Vent System to protect radioactive materials exhaust. (French, German, Switzerland, Finland, Norway)



Objectives of Filtered Vent System

- (1) Preventing C/V rapture
- (2) Preventing Radioactive material exhaust

Fukushima Daiichi NPP

- #1 C/V 7bar + Vent + H₂ Explosion ~1day
- #2 C/V 7bar + No Vent + C/V rapture ~3.5days
- #3 C/V 6bar + Vent + H₂ Explosion ~3days

Prevent **over-pressure** C/V rapture + Exhaust of RI and H₂
 → Filtered Containment Venting System (FCVS)
 Feed and Bleed under Long SBO & LUHS
 Backfitted on 1992 for (mitigation of Sever Accident)

Prevent **over-temperature** C/V rapture + H₂ leakage
 → Special Emergency Heat Removal System (SEHR)

JSME visit Leibstadt NPP, Swiss, on Nov.11,2011

Visit Chooz NPP, EDF France




Visit Leibstadt NPP, KKL, Switzerland



FCVS: Filtered Containment Venting System

■ Vent valve will be open by manual shaft when SBO




Backfitted on 1992 for (mitigation of Severe Accident)

SEHR: Special Emergency Heat Removal System

■ After the TMI-2 accidents, KKL back-fitted the DiD3 (additional C/V cooling) and DiD4 (mitigation of Severe Accident).

DiD: Defense in Depth



Two D/G for SEHR

Special Power Generator on Height


■ 4000kVA mobile gas-turbine generator at 31m parking (Hepco)




■ Gas-turbine generator will be installed at 25m (Chubu Electric)




Countermeasure 2. Heat Removal System



Heat Sink by Sea Water Network



Sustainable Energy in German: Only 1.9% Solar



Capacity Factor
Nuclear: 20.3 TW
Solar: 17.0 TW

Power Source in German 2010 (Total 6.2x10¹¹kWh, Tentative)
Sustainable Energy Statics

Killer Heat Wave in Europe

The death toll in France, Killer heat
Total 50,000 died in 2003 and 2006



Elbe River, Dresden, German, July 2006




干上がったエルベ川
欧州【AFP=時事】



Global Warming brings heat waves
CO₂ may be much danger than radio activities

The death toll in France during a Europe-wide July heat wave has reached an estimated 40. But it was nothing like the summer of 2003, when killer heat combined with social dysfunction, leaving 15,000 dead.

Fossil Energy Estimation in Future



Nuclear Education for Saudi Arabia

King Abdulaziz University asked to Hokkaido University for Nuclear Education

Oil in Saudi Arabia would be empty within 60 years if they wouldn't use nuclear



Progress in Kuala Lumpur, Malaysia



Nuclear Education in Malaysia



Conclusion

- Fukushima Daiichi NPP accident would be terminated, if sufficient examination lead to install countermeasures for tsunami, such as water proof door, mobile power, etc.
- In Europe, it had already installed the Heat Removal System and Filtered Venting System from the lessons of **TMI and Chernobyl Accidents**.
- Vent line should be independent from SGTS/HVAC line.
- From the Lessons of Fukushima-Daiichi Accidents, we should achieve the 1st class Nuclear safety in the world NPPs.
- Solar and sustainable energy will not sufficient to replace the nuclear energy. Both the energy should be used in future.
- Nuclear education is very important to maintain the Nuclear safety technology and safety culture in the world.